

# APPROVAL OF SERVICE SUPPLIERS

This is to certify that

**WKB - Fire Protection**  
**Buxtehude, Germany**

is granted acceptance for

**Inspection and maintenance of fire extinguishing equipment and systems , in accordance with Class Programme DNVGL-CP-0484.**

This service supplier certificate will be accepted for use with all rule sets published by DNV GL.  
**See the following page(s) for details regarding application.**

This Certificate is valid from **2020-11-23** to (inclusive) **2023-11-22**.

This Certificate is issued on **2020-11-18**.



for **DNV GL**

This document has been digitally signed and  
will therefore not have handwritten signatures

**Buck, Jochen**  
**Principal Surveyor, Team Leader**

This Certificate may be withdrawn if:

1. The service provided has been improperly carried out or the results improperly reported.
2. The surveyor has found any deficiencies in the accepted operating systems of the service supplier.
3. The firm has failed to inform of any major changes having effect on the quality of the service rendered.
4. The conditions listed in the certificate are changed and/or are not fulfilled.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV GL AS, its parent companies and subsidiaries as well as their officers, directors and employees ("DNV GL") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.





Certificate No: **AOSS0000HG7**

**Application:**

**Approval is granted for the following services:**

CO<sub>2</sub> fire extinguishing systems (high and low pressure)  
halon and other gaseous fire extinguishing systems  
dry powder fire extinguishing systems  
pressure water spraying systems (sprinkler and deluge) incl. water mist systems  
portable fire extinguishers  
mobile fire extinguishers  
hydro-static testing of pressure vessels  
level check of CO<sub>2</sub> and other gas cylinders  
examination of foam concentrates  
fixed fire extinguishing systems for deep fat cooking

**Remarks:**

**A list of approved supervisors and inspectors is to be maintained by the approved service supplier and DNV GL shall be informed upon relevant changes.**